

Tamilnadu Fire & Rescue Service Department

RC. No : 6/2025
Date : 05.02.2025

Fire & Rescue Station
Rasipuram - 637 408

No Objection Certificate


Sub : Tamilnadu Fire & Rescue Services - Office of the Fire and Rescue Station,
Rasipuram - Issue to No Objection Certificate for School Recognition - Regarding

Ref : 1. G.o.Ms. No. 117 School of Education (2) Dept. Date : 07.09.2004
2. G.o.Ms. No. 122 School of Education (2) Dept. Date : 14.09.2004
3. G.o.Ms. No. 123 School of Education (2) Dept. Date : 14.09.2004
4. Application Dated 03.02.2025 from the **The Secretary, M/S. Green World
Excel School CBSE, Moolapallipatty 637406**

With reference to the above Government Orders and an Application by **M/s, Green World Excel School CBSE**, S.F. No : 250/3, 250/4, 303/2, Attur Main Road, Moolapallipatty Post, Namagiripet Via, Rasipuram Taluk, Namakkal District was inspected on 04.02.2025 by **Mr.V.Palagara Ramasamy, Rasipuram Station Officer** in the view of our Fire and Rescue Services Department there is **No Objection** for the granting Recognition to the above said school.



The Secretary,
M/s, Green World Excel School CBSE,
S.F. No : 250/3, 250/4, 303/2,
Attur Main Road, Moolapallipatty Post,
Namagiripet Via, Rasipuram Taluk,
Namakkal District



நிலைய அலுவலர்
தீயணைப்பு-மீட்டிங் பணிகள் நிலையம்
இராசிபுரம்-637 408
நாமக்கல் மாவட்டம்

Copy : District Officer, Fire and Rescue Services, Namakkal

Copy : Deputy Director, Tamilnadu Fire and Rescue Services, Salem Region, Salem

நிபந்தனைகள்

1. தேசிய கட்டிட விதியின் படி NBC- PART-IV, 2016, இந்திய தரக்கட்டுப்பாடு BIS-14435-1997-ன் படி தீயணைப்பு மீட்பு பணிகள் துறையினரால் குறிப்பிடப்பட்டுள்ளவாறு தீ தடுப்பு சாதனங்கள் அமைக்கப்பட வேண்டும்.
2. தீ பாதுகாப்பிற்கென்று 10000 லிட்டர் கொள்ளளவு கொண்ட மேல்நிலை நீர் தேக்க தொட்டி ஒன்று அமைக்கப்பட வேண்டும்.
3. 450 LPM திறன் கொண்ட Fire Pump ஒன்றும் மேல்நிலை தொட்டியின் அருகில் அமைத்து Hose Reel Hose System பொருத்தப்பட வேண்டும்.
4. Manually Operated Electronic Fire Alarm System பொருத்தப்பட வேண்டும்.
5. தீ பாதுகாப்பிற்கு வைத்திருக்கும் தீயணைப்பாளர்களை கால முறையாக மறு நிரப்பம் செய்து எப்போதும் நல்ல நிலையில் இயங்கக் கூடியதாக வைக்கப்பட வேண்டும்.
6. அங்கீகரிக்கப்பட்ட தரமான மின் சாதனங்கள் (ISI) சான்ற பெற்றவை மட்டுமே பயன்படுத்த வேண்டும்.
7. வெளியேறும் வழி எப்போதும் தடையின்றி இருக்க வேண்டும்.
8. இந்த நிபந்தனைகள் ஏதேனும் மீறப்பட்டால் இந்த தடையின்மை சான்று தானாக ரத்தானதாக கருதப்படும் என விண்ணப்பதாரருக்கு தெரிவிக்கப்படுகிறது.


நிலைய அலுவலர் 2125
தீயணைப்பு-மீட்பு பணிகள் நிலை
இராசிபுரம்-637 408
நாமக்கல் மா.பட்டம்